

Description: 37 Core Cu PVC FRPVC SWA ECC FRPVC, 1000 V
37 Core Cu PVC LHFRPVC SWA ECC LHFRPVC, 1000 V

F4CC Dnnn ZZ 121 0K0S
F4CC Dnnn ZZ 222 0K0S

Specification: SANS 1507

Last updated: January 2026

PHYSICAL	...Dnnn	D915	D925	D004
Conductor size	mm ² nom	1,5	2,5	4
Conductor diameter	mm app	1,6	2,1	2,6
Insulation diameter	mm app	3,2	3,7	4,6
Bedding diameter	mm app	25,6	29,5	36,1
Armour diameter	mm app	29,6	33,5	40,1
Cable diameter	mm app	33,5	37,8	45,3
Length of cable on a drum	m	500	500	500
Cable mass (approximate)	kg/m app	2,3	3,0	4,1
Gross mass on drum	kg app	1253	1657	2318
Bending radius	mm min	335	378	453
ELECTRICAL				
DC Resistance @ 20 °C	Ω/km	12,100	7,410	4,610
AC Resistance @ 70 °C	Ω/km	14,478	8,866	5,516
Reactance X+	Ω/km	0,150	0,137	0,137
Impedance Z+	Ω/km	14,478	8,867	5,518
CURRENT RATINGS				
Ground	Amps	9	12	16
110 Ducts in ground	Amps	7	10	12
Air in Shade	Amps	9	12	16
Air in sunlight	Amps	7	9	12
SHORT CIRCUIT RATING				
Symmetrical (160 °C)	kA (1 sec)	0,17	0,29	0,46
Earth fault (160 °C)	kA (1 sec)	10,15	11,66	14,05
(Three Phase) Volt Drop	mV/A/m	25,1	15,4	9,6

* In practice the earth fault rating must be limited to symmetrical fault rating,

Note ratings assume that all conductors carry equal currents simultaneously

The current ratings above are based on standard laying conditions for a single circuit in isolation as follows:

- Conductor temperature = 70 °C
- Soil thermal resistivity = 1,2 K·m/W
- Soil temperature = 25 °C
- Air temperature = 30 °C
- Depth of burial = 500 mm
- 5% tolerance on dimensions



DISCLAIMER: CBI reserves the right to change product specifications from time to time to effect improvements and /or enhancements and accepts no liability arising from any difference between the published parameters of this data sheet and the finished product, unless by prior written agreement.

POWER BY INNOVATION... INNOVATION THROUGH PARTNERSHIPS

CBI-electric: african cables | a division of ATC (Pty) Ltd | Registration No. 1955/003773/07
PO Box 172, Vereeniging 1930 | Steel Road, Peacehaven, Vereeniging, 1939, South Africa
Tel: +27 16 430 6000 | www.cbi-electric.com | Member of the REUNERT Group | B-BBEE Level 1
ISO 9001 | ISO 14001 | ISO 45001