

Standard laying conditions	Other laying conditions
Air temperature 30°C	$I_{standard}$ = Standard current rating in air
	I_{rated} = $I_{standard} \times k_1 \times k_2 \times k_3 \times k_4$
	k_1 = Table 1
	k_2 = Table 2
	k_3 = Table 3 to Table 4
	k_4 = Table 5

Table 1 – Rating factor for variation in temperature of air (k1)

Insulation Type	Maximum conductor temperature, °C	Air temperature, °C							
		15	20	25	30	35	40	45	50
PVC D2	70	1.17	1.12	1.07	1.00	0.93	0.86	0.77	0.71
XLPE	90	1.13	1.09	1.04	1.00	0.95	0.91	0.86	0.82

Table 2 – Rating factors for cables, laid in direct sunlight (k2)

Rating factors for direct solar radiation (cables installed in direct sunlight)	Conductor size, mm ²			
	1.5–16	25–95	120–185	240–1000
	0.65	0.55	0.50	0.45

Table 3 – Group Rating factors for twin or multicore cables installed in air on ladder racks or perforated cable trays (k3)

Number of Cables in Layer	1	2	3	4	5	7	10
1.1.1 Single layer 	0.95	0.84	0.8	0.77	0.76	0.74	0.73
Two layers 				0.71	0.66	0.59	0.53
More than two layers 				0.71	0.64	0.55	0.48

NOTE : No derating needs to be applied when cables are installed in a single layer and spaced one cable diameter apart.

POWER BY INNOVATION... INNOVATION THROUGH PARTNERSHIPS

Table 4 - Group rating factor for trefoil groups of three single core cables installed in air on ladder racks or perforated cable tray (k3)

Number of racks or trays	Number of trefoil groups per rack or tray		
	1	2	3
1	1.00	0.98	0.96
2	1.00	0.95	0.93
3	1.00	0.94	0.92
6	1.00	0.93	0.90

Cable spaced as shown

Table 5 - Additional rating factor to be applied to the single layer factors of Table 3, when two or more racks or trays are installed one above the other with 300mm vertical spacing (k4)

Number of Racks or Trays	Additional rating factor
2	0.95
3	0.93
6	0.90

Cables installed touching

Disclaimer: The cable rating factors are designed as a guide for calculation of a wide range of cable types and cables sizes. While single rating factors remain reasonably accurate, the more factors that are applied simultaneously, larger possible variances arise. While every effort has been made to ensure the information contained herein is correct, CBI-electric: african cables disclaim responsibility for any action, proceedings, liabilities, claims, damages, costs, losses and expense in relation to, or arising out of any use of the factors. Due to continuous improvement CBI-electric: african cables reserves the right to change the above without notice.